





P.O. Box 343  
 1175 East Third Street  
 Colville, WA 99114  
 (509) 684-2534

## 1950 GAL WATER TANK



### TOP VIEW



#### Tank Dimensions

12' 6" LONG  
 5' 8" WIDE  
 4' 11 1/2" TALL

#### Hole Dimensions

14' 6" LONG  
 8' WIDE  
 6' DEEP

Tank will be guaranteed for 1 year from time of delivery not to leak more than 1% of total volume per 24 hours if:

1. Tank hole is flat and level.
2. Tank is set on level 4" bedding material ( sand, pea gravel ).
3. Tank is backfilled prior to filling.

Test Procedures: Fill tank to liquid level 1" from the top, wait 24 hours, refill tank if required, wait 2 to 4 hours and test.